



☎ : 27425511

Fax No. : (020) 27425600

E-mail : pcmc@vsnl.com

**PIMPRI CHINCHWAD
MUNICIPAL CORPORATION**

Pimpri - 411 018.

No. : पा. पु. भँब. का. वि / 273 / 2020

Date 27 / 11 / 2020

To,

The Principal,

Angel Public School,

Kiwale, pune.

Subject: Water sample Potability Certificate.

Drinking water sample provided by Angel Public School, kiwale, pune on Date: 23/11/2020 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no.ws /lab /271/2020 dated 27/11/2020 & ws /lab /270/2020 dated 25/11/2020 the water Sample is safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory.

Executive Engineer (WS)
Pimpri Chinchwad Municipal Corporation
Pimpri -18

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION

No-WS/Lab/271 /2020



Date -27 / 11 /2020

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER


NAME - Angels public school

DATE OF EXAMINATION -23 / 11 /2020

ADDRESS - kiwale

SOURCE → Filter water

NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN / 100ml		REMARK
			Coliforms	E. Coli	
1	water sample	Nil	0/100ml	-	potable
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					


CHEMIST
 STP. Laboratory, Sec.-29
 Nigdi-411054.

PIMPRI CHINCHWAD MUNICIPAL CORPORATION
(W/S) DIVISION



Report Of Chemical Examination Of Water

NO-WS / LAB / 27^o / 2020

DATE - 25 / 11 / 2020

DATE OF RECEIPT - 23 / 11 / 2020

DATE OF EXAMINATION - 23 / 11 / 2020

NAME - Angels public school


ADDRESS - kiwale

SOURCE → filter water.

No.	Tests	I. S Standard for Drinking Water	Results mg/lit	Results mg/lit	Conclusion
1	Turbidity	5 N.T.U max	0.19 NTU	/	
2	pH	6.5 to 8.5	8.28		
3	Total Hardness (AS CaCo ₃)	300 mg/lit max	36 mg/lit		
4	Chloride	250 mg/lit max	4 mg/lit		
5	Calcium	75 mg/lit max	6.41 mg/lit		

NOTE-SAMPLE NOT DRAWN BY THIS LABORATORY

COPY TO-


CHEMIST
 WTP. Laboratory, Sec - 2^a
 Nigdi-411 014

Outward No : 202/21

Date : 27th July 2021


To,
PRINCIPAL
Angels Public School ,
A/P. Kiwale , Tal. Haveli, Dist. Pune . 412101.

SCHOOL SANITATION CERTIFICATE

It is certified that navgrah shikshan prarak mandal's Angels Public School , A/P. Kiwale , Tal. Haveli, Dist. Pune . 412101. When the school is inspected for health & sanitation purpose, all the sanitation and health facilities in the school are adequate available, including urinals, WC, sufficient Drainage system as per student's strength.

This certificate is being issued as request by the school principal, The above certificate is valid for the period of one year.

Health Officer

F.O.R. 
प्रभारी वैद्यकीय अधिकारी,
किबळे दवाखाना,
पिंपरी-विंचवड महानगरपालिका